



CITY OF GREENVILLE

Dept. of Planning & Zoning
100 Public Square
Greenville, OH 45331
Phone: (937) 548-4930, Web: www.cityofgreenville.org



OHIO – E MAIN TRAFFIC SIGNAL PROJECT ADDENDUM #1 – FEBRUARY 5, 2016

Question cut-off was February 4, 2016 at 10:00 a.m., as stated in the Advertisement for Bids.

BIDS OPEN: FEBRUARY 11, 2016 AT 10:00 A.M. LOCAL TIME

Question #1 – The bid tabs call out 500 feet of 3/C #6 Service cable for the project. Is this footage correct? If so, would you please let me know where the cable terminates as the plans do not address it?

Answer #1 - There is a transformer on the northeast corner of Main/Virginia that could be used. However, if this is not feasible, the next closest transformer is east of Virginia, on the north side of Main, directly across from Hiawatha. The quantity of 500 feet should allow for the transformer at Hiawatha to be connected to, if that is necessary.

Question #2 - Will the 3 conductor, 6 AWG Service cable be installed underground or overhead? If it is to be installed underground, will it be in existing conduit or will conduit need to be installed as part of the pay item and what size would the conduit be?

Answer #2 - The Service Cable is proposed to be installed overhead. The plans indicate that the power service is to be installed on pole, P1 (NE corner), and then feed into the proposed cabinet via conduit, which is specified on the plans.

The engineer's estimate for this project is \$156,500.00.

Plan Holders include: Security Fence Group (Dayton), and Capital Electric (Dayton).

End of Addendum #1